

# F25016 April Russell Design Ltd

89 Larkhall Rise

Tuesday, 16 August 2016

Prepared For April Russell Design Ltd

## Identified 2 Issues

Colin Symonds

Mr Carpet Ltd



### Issue 1

Top floor bathroom will require 12mm shim and tile edge as shown. However if builders lay 6mm ply on the landing it will only need 6mm shim and tile edge? NO PLY LAID YET.

---



### Issue 2

Master bedroom to en-suite bathroom doorway requires 6mm shim and tile edge at present but if builders are laying 6mm plywood then easy shim will not be required.

---