

# P27209 Radford

16 Hillier Road SW11 6AU

Wednesday, 24 August 2016

Prepared For Radford

**Identified 5 Issues**



Colin Symonds

Mr Carpet Ltd



### Issue 1

Satin aluminium tile edge specified at bathroom doorways

---



### Issue 2

Satin aluminium tile edge & 6mm easy shim ramp required at 1st floor bathroom doorway to raise height of carpet to meet tiles.

---



### Issue 3

Top of basement stairs will require a nosing to be installed by your builder to facilitate the finish of the carpet at the top of the riser

---



### Issue 4

The carpet will finish here at the top of the riser and will not meet the existing tile finish - nosing required by others as detailed in previous photograph

---



### **Issue 5**

The bottom step on the basement flight of stairs will be turned under on the tread at the juncture where it meets the boxed off pipe work as this boxing finishes around a third of the way across the width of the bottom riser

---